

# ADDENDUM NO. 1

## GLENRIDGE SEWER PUMP STATION BUILDING PROJECT

August 9, 2019

The contract documents for the above-referenced project are hereby modified or explained further as follows:

### CHANGES TO SPECIFICATIONS:

1. **Bid Item No. 6: BUILDING, REVISE to the following:**

BUILDING shall be paid for at a lump sum price.

The contract lump sum price paid for BUILDING shall include full compensation for furnishing all labor, materials, tools, equipment, and incidentals and for doing all the work involved with BUILDING, complete in place including excavation, dewatering (if necessary), ~~pick-up of access extension and~~ modification of existing sewer lift station, foundations, backfill, concrete, rebar, concrete masonry unit (CMU) block, grout, louvers, vents, door, hardware, roof framing, roof sheathing, roof self-adhered membrane underlayment, sealant, fasteners, connections, anchors, and mechanical systems for the complete structure as shown on the plans, as specified herein, and as directed by the Engineer.

Exterior treatments shall be paid for separately under EXTERIOR FINISHES.

2. **SP-27 DISTRICT FURNISHED MATERIAL, REVISE to the following:**

TCPUD to furnish:

1. Caterpillar C4.4 60eKW (75 kVA) Generator Set. Contractor shall provide required attachments including but not limited to exhaust pipe, vent pipe, etc. Generator is available for inspection during bid.

**TCPUD to furnish and install:**

2. Smith and Loveless pump station manway extension. ~~Contractor responsible for welding extension to existing access and modifying appurtenances.~~ The TCPUD will weld the extension to existing pump station access and modify existing pump station appurtenances as necessary in advance of building construction.

Contractor is responsible for pick-up of ~~both items~~ Generator Set from District yard and delivery to project site. Contractor shall notify District 48 hours in advance of pick-up.

The foregoing requirements are in modification of and supplemental to the original contract documents, and in case of conflict, shall govern. All other provisions of the contract documents remain unchanged and shall be in effect.

Bidders shall acknowledge receipt of this Addendum and other Addenda issued in the blanks provided on the Bid Proposal Form. Bidders who fail to acknowledge this Addendum in the manner specified may have bid proposals rejected.

Sincerely,



Jon LeRoy, PE  
Planning Engineer

cc: All Planholders